



GHAZIABAD TESTING LABORATORIES PVT. LTD.

TEST REPORT


Issued To,
M/s Maheshwari Electrical Mfrs. Pvt. Ltd.
AO-50/51/52, Amrit Steel Compound,
South Side G.T. Road, Near Lal Kuwan,
Ghaziabad (U.P.) 201009

Report No. : 100-231127-675
Report Date : 30-11-2023
Sample Received On : 30-11-2023
Analysis Date : 30-11-2023
Report Prepared on : 30-11-2023
Sampled by : Customer

Sample Description : Hot Dip Galvanized Ladder Cable Tray(450x75x2mm)
Condition of the Sample on receipt : Received in Good Condition

Parameter	Unit	Test Method	Result	Limits as per IS: 4759- 1996
<u>Galvanizing Test</u>				
Adhesion Test	-	IS: 2629-1985	Passes the Test	Shall pass pivoted hammer test.
Uniformity Test	-	IS: 2633-1986	Passes the Test	The sample shall with stand Four dips of one minute each.

Remark-Sample meets the requirement as per specified limits laid down in IS: 4759- 1996 as observed for the above test parameters only.



*****End of Report*****

Note:

- ❖ This Test report conforms to above test parameters only submitted for testing.
- ❖ Decision Rule applied- Yes/ No ✓ UM ±
- ❖ The sample description is not verified in all cases and is given as described by the customer.
- ❖ Samples not drawn by us and the analysis conducted as received basis unless specified otherwise.
- ❖ Tested sample will be disposed off after 30 days from the date of issue of test report unless until specified by customer.
- ❖ Complaints about this report should be communicated in writing within seven days of issue date of this report.
- ❖ This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of Law.
- ❖ shall not be used in the advertising media without our prior permission from the Director.
- ❖ Laboratory shall maintain the confidentiality of all information related to the samples & Test Reports.

